Certificate No.: 2531-CPR-CSP11036



CERTIFICATE OF CONSTANCY OF PERFORMANCE

Issued by DBI Certification, notified body No. 2531.

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

45681-290 Analogue Addressable Type A Integrated Base Sounder with Short Circuit Isolator

The product fulfils the essential characteristic:

See Annex 1

Intended use: Applications related to automatic fire alarm systems

Placed on the market under the name or trade mark of:

Apollo Fire Detectors Limited 36 Brookside Road, Havant, Hampshire, PO9 1JR, UK

and produced in the manufacturing plant:

Apollo Fire Detectors Limited
36 Brookside Road, Havant, Hampshire, PO9 1JR, UK

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standards

EN 54-3:2001/A1:2002/A2:2006 : Fire detection and fire alarm systems - Part 3: Fire alarm devices - Sounders EN 54-17:2005 : Fire detection and fire alarm systems - Part 17: Short-circuit isolators

under system 1 for the performance set out in this certificate are applied and that the performance of the construction product is assessed to remain constant.

The attached annexes form part of this certificate.

Date of issue: 2019-10-31.

This certificate will remain valid as long as neither the harmonized standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly unless suspended or withdrawn by the notified product certification body.

This certificate was first issued 2019-10-31.

Merete Poulsen Responsible for evaluation Allan Laursen
Responsible for certification decision

Certificate No.: 2531-CPR-CSP11036





Annex 1

EXTENT

Type:

45681-290 Analogue Addressable Type A Integrated Base Sounder with Short Circuit Isolator

Sounder Tones:

Alert (High Tone Range) -870Hz Continuous - with variable volume control Evacuate (High Tone Range) - 0Hz (1s) - 500Hz/1200Hz (3.5s) with variable volume control

Performance

Essential characteristics	Clauses in EN 54-3:2001	Performance
Performance under fire conditions	4.2, 4.3, 5.2, 5.3	Pass
Operational reliability	4.4, 4.5, 4.6, 5.4, C4	Pass
Durability of operational reliability and response delay; temperature resistance	5.5, 5.6, 5.7, 5.8, 5.9	Pass
Durability of operational reliability; humidity resistance	5.8, 5.9, 5.10	Pass
Durability of operational reliability; corrosion resistance	5.11	Pass
Durability of operational reliability; vibration resistance	5.12 to 5.15	Pass
Durability of operational reliability; electrical stability	5.16	Pass
Durability of operational reliability; resistance to ingress	5.17	Pass

^{5.6} and 5.10 applies only to outdoor sounders or outdoor voice sounders.

^{5.16} applies only to sounders or voice sounders with active electronic components

Essential characteristics	Clauses in EN 54-17:2005	Performance
Performance under fire conditions	5.2 1)	Pass
Operational reliability	4	Pass
Durability of operational reliability;	5.4, 5.5	Pass
temperature resistance		
Durability of operational reliability;	5.9 to 5.12	Pass
vibration resistance		
Durability of operational reliability;	5.6, 5.7	Pass
humidity resistance		
Durability of operational reliability;	5.8	Pass
corrosion resistance		
Durability of operational reliability;	5.3, 5.13	Pass
electrical stability		

¹⁾ This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices



[–] extracts only with written permission from DBI Certification A/S.

Certificate No.: 2531-CPR-CSP11036





Annex 2

TEST DOCUMENTATION

Accredited Laboratory	Report no.	Date
BRE	P109696 Issue: 1	15 August 2018
BRE	TE 222021	28 September 2005
BRE	TE-P105642-1001 Issue: 1	21 March 2019

TECHNICAL BASIS

File Number	Title
45681-290	Build Standard

