

BRE Global

Notified Body No. 0832

BRE Global Limited
Bucknalls Lane, Garston, Watford,
Hertfordshire, UK, WD25 9XX
Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
Web: www.breglobal.com

Certificate of constancy of performance

0832-CPR-F2103

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9th March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product(s)

55000-001 Intelligent Sounder Open-Area (Red)

(For full product details and conditions of use refer to appendix)

Placed on the market under the name or trade mark of:

and produced in the manufacturing plant(s):

Apollo Fire Detectors Limited
36 Brookside Road
Havant
Hampshire
PO9 1JR
United Kingdom

Apollo Fire Detectors Limited
36 Brookside Road
Havant
Hampshire
PO9 1JR
United Kingdom

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-3:2001 + A1:2002 + A2:2006 - Sounders

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure

the constancy of performance of the construction product.

This certificate was first issued on 23 January 2019 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 23 January 2019

Date of Issue: 23 January 2019

Issue number 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.

BRE Global Limited

Bucknalls Lane,
Garston, Watford,
Hertfordshire, UK,
WD25 9XX

Notified Body No. 0832

Telephone: +44 (0) 333 321 8811
Fax: +44 (0)1923 664603
Email: enquiries@breglobal.com
web: www.breglobal.com

APPENDIX to Certificate of constancy of performance: 0832-CPR-F2103**55000-001 Intelligent Sounder Open-Area (Red)****Bases:**

45681-517 Enhanced deep isolating base (White)

45681-518 Enhanced deep isolating base (Red)

Sounder Tones:

Apollo standard – 840HZ, 0.5s / 558Hz, 0.5s

Dutch (slow whoop) – 500-1200Hz in 3.5s, 0.5s off

German DIN – 1200-500Hz over 1s

Variants:

55000-002 – Intelligent Sounder Open-Area (White)



P Halligan, Certification Manager,

On behalf of BRE Global Limited

Date of First Issue: 23 January 2019

Date of Issue: 23 January 2019

Issue number: 01

To check the validity of this certificate, please contact us on +44 (0)333 321 8811 or email enquiries@breglobal.com.