

## Certificate of Constancy of Performance

**Certificate No. 2544-CPR-30940-F01-22**

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (CPR)

*This certificate applies to the construction product*

### Alarm transmission and fault warning routing equipment

with name and/or type designations

#### **DualCom Pro 2**

*Placed on the market by*

#### **CSL DualCom Ltd.**

Building 4, Croxley Park, Hatters Lane, Watford, WD18 8YF

*Produced in the manufacturing plants by*

#### **Tenstep Ltd.**

Unit 14, Oldbury Business Centre, Oldbury Rd,  
Cwmbran, NP44 3JU

#### **SRXGlobal (M) SDN. BHD**

Tingkat 4, 12B Jalan Bayu, Kawasan Perindustrian  
Hasil, 81200 Johor Bahru Johor


*This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performance described in Annex ZA of the standard*

### **EN 54-21:2006**

are applied and that the product fulfils all the prescribed requirements

This Certificate is valid until 2026-03-18

Høvik, Norway 2026-03-18  
for Applica Test & Certification AS



Jan Rune Pedersen,  
Certification Manager



Notified Body (NB) 2544

Certificate History		
Revision	Description	Issue Date
-	Initial Issue	2022-03-18

Products covered by this certificate comply with EN 54-21:2006		
Product Name	Product Configuration	Type of transmission system in accordance with EN 54-21:2006
DualCom Pro 2	DigiAir Pro 2 - Radio	Type 1
	GradeShift Pro 2 – Radio/Radio	
	GradeShift Pro 2 – LAN/Radio	

- **Application/Limitation**

- To be used in accordance with the supplier's installation instructions
- Suitable for indoor application
- Shall be installed in a housing that is compliant with the requirements of EN 54-21:2006
- The power supply equipment used shall comply with EN 54-4:1997+A1:2002+A2:2006

Documents Reviewed	
Document ID	Description
Technical Report 30799	EN 54-21:2006
30943_FPC_03_Report from Inspection	FPC report Tenstep
30956 FPC_03_Report from Inspection	FPC report SRX Global

*Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of the product and/or production process may render this certificate invalid.*

## Terms and Conditions

The certificate is subject to the following terms and conditions:

- The Certificate is only valid for the products listed above
- The Certificate remains valid based upon satisfactory annual factory production control audits

The following may render this Certificate invalid:

- Changes in the design, construction and/or software of the products
- Changes in the test methods and/or factory production control requirements included in the harmonised standards, used to assess the performance of the declared characteristics
- Significant changes in the manufacturing plants

END OF CERTIFICATE

**Notice: The certificate is subject to terms and conditions overleaf. Any significant changes in design, construction of the product and/or production process may render this certificate invalid.**

Applica Test & Certification AS, Veritasveien 1, 1363 Høvik, Norway. [www.applica.no](http://www.applica.no)